



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5142CL0468

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Hylomar Ltd. Cale Lane, GB- Wigan WN2 1JT
Distributor <i>Vertreiber</i>	Hylomar Ltd. Cale Lane, GB- Wigan WN2 1JT
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for gas and water installations for metallic jointing, non hardening (5142)
Product Description <i>Produktbezeichnung</i>	Non-hardening sealing material
Model <i>Modell</i>	HYLOMAR M
Test Reports <i>Prüfberichte</i>	laboratory control test: 15/064/5142/01 from 11.03.2015 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-2 (01.08.1997)

Date of Expiry / File No. 16.12.2020 / 15-0164-GNV
Ablaufdatum / Aktenzeichen

16.11.2015 Rie A-1/2 *i.H. U. Kling*
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
HYLOMAR M	class: B temperature range: -20...+125 °C max. operating pressure: 0,2 bar	

