



CONSIDER THIS DRAWING ONLY AS EXAMPLE
DON'T FOLLOW THIS SCHEME FOR MAKING THE PIPELINE

TC	ECODRY LEAVING WATER TEMPERATURE	FS	WATER TANK LEVEL SWITCH
TR	PROCESS RETURN TEMPERATURE	FIN	FILTER INLET PRESSURE (OPTIONAL)
TA	AMBIENT TEMPERATURE	FOUT	FILTER OUTLET PRESSURE (OPTIONAL)
PS	PROCESS PRESSURE		
LT	TANK WATER LEVEL		

PIPING ONLY IN STAINLESS STEEL
OR PE/PVC (SUGGESTED)

* valve DN25/40
for filling/drainng
and flushing

VALVES, FLANGES, COUPLINGS, PIPING, FRAMES AND
BASEMENTS ARE NOT INCLUDED IN EQUIPMENT SUPPLY



NEW APPROACH
FOR COOLING
AND
TEMPERATURE CONTROL

Via Pisana, 318 - 50018 SCANDICCI (Firenze) ITALY
Tel. +39/055722091 - Fax +39/0557311271 - Part. IVA it 00390240489

OGGETTO P&ID	disegnato Tullio Betti	controllato Tullio Betti	scala data 16/07/2012 foglio 1 di 1
	N° DISEGNO 1PS12077-38		00