

PRESSURE		TEMPERATURE		SPECIFIC ENTHALPY								SPECIFIC VOLUME STEAM	
bar g	psi	°C	°F	WATER Sensible Heat h _f		EVAPORATION Latent Heat h _{fg}		STEAM Total Heat h _g		m ³ /kg	ft ³ /lb		
				kJ/kg	btu/lb	kJ/kg	btu/lb	kJ/kg	btu/lb				
0.00	0.0	100.0	212.0	419.0	180.2	2257.0	970.3	2676.0	1150.5	1.673	26.80		
0.10	1.5	102.7	216.8	430.2	185.0	2250.2	967.4	2680.4	1152.4	1.533	24.56		
0.20	2.9	105.1	221.2	440.8	189.5	2243.4	964.5	2684.2	1154.0	1.414	22.65		
0.25	3.6	106.3	223.3	445.7	191.6	2240.3	963.2	2686.0	1154.8	1.361	21.80		
0.30	4.4	107.4	225.3	450.4	193.6	2237.2	961.8	2687.6	1155.5	1.312	21.02		
0.40	5.8	109.6	229.2	459.7	197.6	2231.3	959.3	2691.0	1156.9	1.225	19.62		
0.50	7.3	111.6	232.9	468.6	201.5	2225.6	956.8	2694.2	1158.3	1.149	18.41		
0.75	10.9	116.3	241.3	487.9	209.8	2213.0	951.4	2700.9	1161.2	0.997	15.97		
1.00	14.5	120.4	248.8	505.6	217.4	2201.1	946.3	2706.7	1163.7	0.881	14.11		
1.50	21.8	127.6	261.7	536.1	230.5	2181.0	937.7	2717.1	1168.1	0.714	11.44		
2.00	29.0	133.7	272.6	562.2	241.7	2163.3	930.1	2725.5	1171.8	0.603	9.66		
2.50	36.3	139.0	282.2	585.0	251.5	2147.6	923.3	2732.6	1174.8	0.522	8.36		
3.00	43.5	143.8	290.8	605.3	260.2	2133.4	917.2	2738.7	1177.4	0.461	7.38		
3.50	50.8	148.0	298.4	623.6	268.1	2120.3	911.6	2743.9	1179.7	0.413	6.62		
4.00	58.0	152.0	305.5	640.7	275.5	2108.1	906.3	2748.8	1181.8	0.374	5.99		
4.50	65.3	155.6	312.0	656.3	282.2	2096.7	901.4	2753.0	1183.6	0.342	5.48		
5.00	72.5	158.9	318.1	670.9	288.4	2086.0	896.8	2756.9	1185.3	0.315	5.05		
5.50	79.8	162.1	323.7	684.6	294.3	2075.7	892.4	2760.3	1186.7	0.292	4.68		
6.00	87.0	165.0	329.1	697.5	299.9	2066.0	888.2	2763.5	1188.1	0.272	4.36		
6.50	94.3	167.8	334.1	709.7	305.1	2056.8	884.3	2766.5	1189.4	0.255	4.08		
7.00	101.5	170.5	338.9	721.4	310.1	2047.7	880.4	2769.1	1190.5	0.240	3.84		
7.50	108.8	173.0	343.4	732.5	314.9	2039.2	876.7	2771.7	1191.6	0.227	3.64		
8.00	116.0	175.4	347.8	743.1	319.5	2030.9	873.1	2774.0	1192.6	0.215	3.44		
8.50	123.3	177.8	352.0	753.3	323.9	2022.9	869.7	2776.2	1193.6	0.204	3.27		
9.00	130.5	180.0	355.9	763.0	328.0	2015.1	866.3	2778.1	1194.4	0.194	3.11		
9.50	137.8	182.1	359.8	772.5	332.1	2007.5	863.1	2780.0	1195.2	0.185	2.96		
10.00	145.0	184.1	363.4	781.6	336.0	2000.1	859.9	2781.7	1195.9	0.177	2.84		
10.50	152.3	186.0	366.8	790.0	339.6	1993.0	856.8	2783.0	1196.5	0.171	2.74		
11.00	159.5	188.0	370.4	798.2	343.2	1986.0	853.8	2784.2	1197.0	0.163	2.61		
11.50	166.8	190.0	374.0	807.0	346.9	1979.0	850.8	2786.0	1197.8	0.157	2.51		
12.00	174.0	191.7	377.0	815.1	350.4	1972.5	848.0	2787.6	1198.5	0.151	2.42		
12.50	181.3	193.0	379.4	823.0	353.8	1966.0	845.2	2789.0	1199.1	0.146	2.34		
13.00	188.5	195.1	383.2	830.4	357.0	1959.6	842.5	2790.0	1199.5	0.141	2.26		
13.50	195.8	197.0	386.6	838.0	360.3	1953.0	839.6	2791.0	1199.9	0.136	2.18		
14.00	203.1	198.4	389.0	845.1	363.3	1947.1	837.1	2792.2	1200.4	0.132	2.11		
14.50	210.3	200.0	392.0	852.0	366.3	1941.0	834.5	2793.0	1200.8	0.128	2.05		
15.00	217.6	201.5	394.6	859.0	369.3	1935.0	831.9	2794.0	1201.2	0.124	1.99		
16.00	232.1	204.4	399.9	872.3	375.0	1923.4	826.9	2795.7	1201.9	0.117	1.87		
17.00	246.6	207.2	404.9	885.0	380.5	1912.1	822.1	2797.1	1202.5	0.110	1.76		
18.00	261.1	209.9	409.8	897.2	385.7	1901.3	817.4	2798.5	1203.1	0.105	1.68		
19.00	275.6	212.5	414.4	909.0	390.8	1890.5	812.8	2799.5	1203.6	0.100	1.60		
20.00	290.1	215.0	418.9	920.3	395.7	1880.2	808.3	2800.5	1204.0	0.095	1.52		
21.00	304.6	217.4	423.2	931.3	400.4	1870.1	804.0	2801.4	1204.4	0.091	1.45		
22.00	319.1	219.7	427.4	941.9	404.9	1860.1	799.7	2802.0	1204.6	0.087	1.39		
23.00	333.6	221.9	431.3	952.2	409.4	1850.4	795.5	2802.6	1204.9	0.083	1.33		
24.00	348.1	224.0	435.2	962.2	413.7	1840.9	791.4	2803.1	1205.1	0.080	1.28		
25.00	362.6	226.1	439.0	972.1	417.9	1831.4	787.4	2803.5	1205.3	0.077	1.23		
26.00	377.1	228.2	442.7	981.6	422.0	1822.2	783.4	2803.8	1205.4	0.074	1.19		
27.00	391.6	230.1	446.3	990.7	425.9	1813.3	779.6	2804.0	1205.5	0.071	1.14		
28.00	406.1	232.1	449.7	999.7	429.8	1804.4	775.8	2804.1	1205.5	0.069	1.10		
29.00	420.6	233.9	453.1	1008.6	433.6	1795.6	772.0	2804.2	1205.6	0.067	1.07		
30.00	435.1	235.8	456.4	1017.0	437.2	1787.0	768.3	2804.0	1205.5	0.065	1.03		
31.00	449.6	237.6	459.6	1025.6	440.9	1778.5	764.6	2804.1	1205.5	0.063	1.00		
32.00	464.1	239.3	462.7	1033.9	444.5	1770.0	761.0	2803.9	1205.5	0.061	0.97		
33.00	478.6	241.0	465.7	1041.9	447.9	1761.8	757.4	2803.7	1205.4	0.059	0.94		
34.00	493.1	242.6	468.7	1049.7	451.3	1753.8	754.0	2803.5	1205.3	0.057	0.91		
35.00	507.6	244.3	471.7	1057.7	454.7	1745.5	750.4	2803.2	1205.2	0.055	0.89		
36.00	522.1	245.9	474.5	1065.7	458.2	1737.2	746.9	2802.9	1205.0	0.054	0.86		
37.00	536.6	247.4	477.4	1072.9	461.3	1729.5	743.6	2802.4	1204.8	0.052	0.84		
38.00	551.1	249.0	480.1	1080.3	464.4	1721.6	740.2	2801.9	1204.6	0.051	0.82		
39.00	565.6	250.4	482.8	1087.4	467.5	1714.1	736.9	2801.5	1204.4	0.050	0.80		
40.00	580.2	251.9	485.5	1094.6	470.6	1706.3	733.6	2800.9	1204.2	0.049	0.78		

SOME USEFUL CALCULATIONS

To calculate actual steam production from the "from & at" rating

$$\text{Actual Output} = \frac{M \times 2257}{A_{h_g} - (T_F \times 4.19)}$$

Where;

- M The "from & at" rating of the boiler shown on the nameplate in kg/h
- A_{h_g} h_g at the working pressure of the boiler in kJ/kg
- T_F Feed tank / howell temperature in °C

for example;

to calculate the actual steam produced by a 5000 kg/hr steam boiler operating at 7 bar with feed water supplied at 85°C

M	5000	kg/hr						
A_{h_g}	2769.1	kJ/kg	(from the table overleaf)					
T_F	85	°C						

$$\frac{5000 \times 2257}{2769.1 - (85 \times 4.19)} = 4677 \text{ kg/hr}$$

To calculate the required blowdown rate of a boiler

$$\text{Blowdown rate} = \frac{F \times S}{B \times F}$$

Where;

- F Feed tank TDS in ppm
- S Actual boiler steam production in kg/hr
- B Maximum TDS allowable in the boiler in ppm

for example;

The steam boiler in the previous example has a feed tank with a TDS of 80ppm, in order to stay below 3500ppm it will need to blowdown at least;

F	80	ppm						
S	4677	kg/hr						
B	3500	ppm						

$$\frac{80 \times 4677}{3500 - 80} = 109 \text{ kg/hr}$$

To calculate the energy lost as a result of boiler blowdown as a percentage of overall fuel costs

$$\text{Energy lost} = \frac{H_f \times BR \times 100}{(A_{h_g} + H_f) \times S}$$

Where;

- T_F Temperature of feed water in °C
- T_B Temperature of steam at boiler pressure in °C
- H_f $(T_F - T_B) \times 4.19$ kJ/kg
- BR Blowdown Rate in kg/hr
- A_{h_g} h_g at the working pressure of the boiler in kJ/kg
- S Actual boiler steam production in kg/hr

To continue the example above;

T_F	85	°C						
T_B	170.5	°C	(from the table overleaf)					
H_f	$(170.5 - 85) \times 4.19 =$	358.2	kJ/kg					
BR	109	kg/hr						
A_{h_g}	2769.1	kJ/kg	(from the table overleaf)					
S	4677	kg/hr						

$$\frac{358.2 \times 109 \times 100}{(2769.1 + 358.2) \times 4677} = 0.27\%$$

To calculate the amount of energy required to raise a mass of steam at a given pressure from a given feed water temperature

$$\text{Energy Required} = \frac{A_{h_g} - (T_F \times 4.19) \times S}{\text{Eff.}}$$

Where;

- A_{h_g} h_g at the working pressure of the boiler in kJ/kg
- T_F Temperature of feed water in °C
- Eff. Boiler efficiency expressed as a decimal
- S Actual boiler steam production in kg/hr

For example

To raise an ACTUAL 5000 kg/hr of steam at 7 bar from 85°C feed water will require;

A_{h_g}	2769.1	kJ/kg	(from the table overleaf)					
T_F	85	°C						
Eff	0.8		(i.e. 80%)					
S	5000	kg/hr						

$$\frac{2769.1 - (85 \times 4.19) \times 5000}{0.8} = 15,081 \text{ MJ/hr}$$

or 4189 kW