PHYSICAL TESTING REPORT





Sussex Brick Limited

Hastings Brickworks Fourteen Acre Lane Three Oaks Sussex TN35 4NB

FAO: Mrs. Gemma Barden

Report of Tests on: HL/M-2017 **Your Reference:** HL/M-2017

Lucideon Reference: (174701)-37476

Date Reported: 14-Nov-2017 **Order Number:** Paid by Cheque

Date Logged: 11-Oct-2017 **Date(s) of Test(s):** 08-Nov-2017 **to** 09-Nov-2017

Determination of Water Absorption

BS EN 772-21: 2011

	Dry Weight	Saturated Weight After 24 Hr Soak	Water Absorption
No.	g	g	%
1	2195	2544	16
2	2269	2618	15
3	2263	2619	16
4	2278	2636	16
5	2176	2518	16
6	2241	2601	16
7	2261	2629	16
8	2278	2644	16
9	2278	2620	15
10	2165	2514	16
Mean	2240	2594	16

Name of organisation carrying out sampling: SUSSEX BRICK

Method of Sampling: Not Supplied

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report



Staffordshire ST4 7LQ

PHYSICAL TESTING REPORT



Sussex Brick Limited

Hastings Brickworks Fourteen Acre Lane Three Oaks Sussex **TN35 4NB**

FAO: Mrs. Gemma Barden

HL/M-2017 Report of Tests on: Your Reference: HL/M-2017

Lucideon Reference: (174701)-37476

Date Reported: Order Number: 14-Nov-2017 Paid by Cheque


Date(s) of Test(s): 14-Nov-2017 **to** 14-Nov-2017 **Date Logged:** 11-Oct-2017

Determination Of Compressive Strength

BS 3921: 1985

	Compressive Strength
No.	N/mm²
1	19.2
2	19.0
3	16.4
4	15.4
5	17.1
6	16.5
7	14.8
8	15.4
9	22.6
10	17.6
Mean	17.4

End of Test Report



Lucideon Limited

Stoke-on-Trent