

Dave Hewitt Business Development Director

Fire Safety Regulation Enforcement Notices



avoid them





When Your Fire Alarm Activates

- Is there a communication link to the emergency services?
- Are you alerted if this link fails?
- Can fire alarm signals still be delivered when this link fails?
- Can fire signals be prioritised while is busy?
- Is the link EN50131/36 compliant?

If you answer No to ANY of the above





CQC places it in special measures

Global fire extinguisher

market to hit \$5 billion



Is My Fire System Adequate?

- Simply having the correct fire alarm installation is not always sufficient.
- Must ensure that a suitable means of alerting the Fire and Rescue Services is available at all times.
- Risks of failure in the method of communication needs to be taken int
- A comprehensive Fire Risk Assessmen take these issues into account





Fire Safety Regulation 169 Union Street London SE1 OLL T 020 8555 1200 x89171

> Minicom 020 7960 3629 london-fire, gov.uk

The Company Secretary Group Limited London Fire and Emergency Planning Authority runs the London Fire Brigade

> Date 31st March 2015 Our Ref 04/190272/RP

London SE1

ENFORCEMENT NOTICE

Notice requiring steps to be taken under Article 30 of the Regulatory Reform (Fire Safety) Order 2005

TO : Name:	Group Limited London, SE1	
Address:		
Concerning Premises at:	House,	Street, Hackney, London EC1V

I Neil Orbell, Assistant Commissioner (Fire Safety Regulation) on behalf of the London Fire & Emergency Planning Authority (the Authority) hereby give you notice that the Authority is of the opinion that you, as a person being under an obligation to do so, have failed to comply with the duties placed upon you by the Regulatory Reform (Fire Safety) Order 2005 (the Order) in respect of the above named premises, the relevant persons who may be on the premises or who may be affected by a fire on the premises.

The matters which, in the opinion of the Authority, constitute the failure(s) to comply with the Order are specified in the schedule attached to this notice.

The relevant extracts of the legislation are attached.

The Authority is further of the opinion that the steps identified in the schedule to this notice must be taken to remedy the specified failure(s) to comply with the Order.

Unless the steps identified in the schedule attached to this notice have been complied with, or such other steps are taken to remedy the failures in consultation with the Authority, you will be deemed not to have complied with this notice.

There may be suitable alternative safety measures, to those detailed in this notice that would meet the requirements of the order. If you wish to propose or discuss any alternative measures you should contact the person named below, before you take any action, to ensure that your proposed measures will be deemed satisfactory by the Authority.

FS03 01 (Rev 11, 10/02/2015)

Page 1 of 6



Corrective actions as outlined Enforcement Notices:



"Fire Alarm signals transmitted to an ARC (Alarm Receiving - or Monitoring - Centre) via a Social Alarm system cannot be delayed by other signals originating from the premises of fire or elsewhere."

Delays in alerting the Fire Brigade arinevitable when Telectors systems share the same communication method as the Fire ADELAYED

Corrective actions as outlined Corrective actions and the Corrective actions actions as outlined Corrective actions actions as outlined Corrective actions



"Fire Alarm signals can be distinguished from other alarm signals at the ARC. This is pertinent when the Fire Alarm system is integrated with Social Alarm systems sharing a single communications link to the ARC"

If Telecare and Fire Alarms share the same telephone line a Fire call cannot be distinguished if a resident call is already in progress, unless this call is



completed or put on hold

Corrective actions as outlined Enforcement Notices:



"The transmission path is continuously monitored so failures in the path can be identified quickly and action taken (as per EN50131/36) so minimising the downtime of the system"

If Telecare and Fire Alarms share the same telephone line and the line fails there is no method of indicating this at the control room.




Corrective actions as outlined of Enforcement Notices:



"The effect of the reliability of the automatic transmission facility is considered (e.g. the effect of fire on the communication lines and equipment)"

Fire alarm signalling must be fitted, maintained and tested to comply with EN54 (EN50136).




How to Avoid Enforcement Notices



- Some products or services may provide answers to individual areas of non-compliance.
- Most of these will be expensive complex and only give partial fixes.
- The typical Telecare or Warden Call system is not suitable for the safe and secure transmission of Fire Alarm signals.
- CSL DualCom SafeLink provides all the answers

Scheme equipment





Monitoring Centre





CONNECTED . SECURE . LIVE

MONITORED BY

DualCom SafeLink

CRITICAL SYSTEM COMMUNICATION







DO NOT TAMPER WITH THIS DEVICE - AUTHORISED ACCESS ONLY WWW.CSLDUAL.COM/HEALTH



Dave Hewitt Business Development Director