
Meeting your commitment to BS5839:Part 6 Sharon Le Corre

Business Development Manager







Why does BS5839 affect my Service?

TSA Code of Practice Review Commissioners Coroner's Court



BS5839 Part 6

The level of protection afforded to occupants needs to be related to the fire risk ...all smoke alarms and heat alarms (if provided) in Grades D, E and F systems should be **interlinked**, such that, when fire is detected by any smoke alarm or heat alarm, an audible fire alarm warning is given by all smoke alarms and heat alarms (if provided) in the premises.





The benefits

More time to get out in an emergency Installation is simple Diagnostics Universal pattress Tunstall compatible





Sharon Le Corre, Business Development Manager

